

# Sigen Hybrid Inverter

50.0 / 60.0 / 80.0 / 100.0 / 110.0 kW



- Seamless switchover, ensuring 0ms load-side disruption operation
- 150% overload for 10s, handling impact loads for smooth device startup
- Minimal size & weight in the same power range, ensures simple installation
- Multi-unit connection via Energy Gateway, flexible expansion from kW to MW
- DC coupling micro-grid solution, simplifies configuration & boosts efficiency

## **Sigen Hybrid Inverter** 50.0 / 60.0 / 80.0 / 100.0 / 110.0 kW

**Preliminary** 

Sigen PV	50М1-НҮВ	60М1-НҮВ	80М1-НҮВ	100м1-нүв	110м1-нүв	Units
DC Input (PV)						
Max. PV input power	100,000	120,000	160,000	200,000	220,000	Wp
Max. DC input voltage	,		1,100			V
Nominal DC input voltage		600 @380/400 Vac, 720 @480 Vac				
Start-up voltage		180				
MPPT voltage range	•		160 ~ 1,000			V
Number of MPP. trackers	4	5	6	8	8	
Number of PV strings per MPPT			2			
Max. input current per MPPT	40					А
Max. short-circuit current per MPPT			60			А
DC Input (Battery)						
Battery module models		SigenStack BAT 12.0				
Battery controller models		SigenStack BC M	12-0.5C-BST / SigenSt	ack BC M2-1C-BST		
System configuration quantity range 1	<del></del>		4 ~ 21			pcs
Max. charge power	55,000	66,000	88,000	110,000	121,000	
Max. discharge power	55,000	66,000	88,000	110,000	121,000	W
Max. operating current			180			A
AC Output (On-grid)						
Nominal output active power	50,000	60,000	80,000	100,000	110,000	W
Max. output apparent power	55,000	66,000	88,000	110,000	121,000	VA
Max. output active power (cosΦ=1)	55,000	66,000	88,000	110,000	121,000	W
Nominal output current @380Vac	76.0	91.2	121.5	151.9	167.1	A
Nominal output current @400Vac	72.5	87.0	115.9	144.9	159.4	А
Nominal output current @480Vac	60.2	72.2	96.3	120.3	132.4	А
Max. output current @380 / 400Vac	83.6	100.3	133.7	167.1	183.8	А
Max. output current @480Vac	66.2	79.4	105.9	132.4	145.6	А
Nominal output voltage		380 / 400 / 480, 3W+N+PE				
Nominal grid frequency	50 / 60					Hz
Power factor	0.8 leading ~ 0.8 lagging					
Total current harmonic distortion	THDi < 3%					
AC Output (Backup)						
Nominal output active power	50,000	60,000	80,000	100,000	110,000	W
Max. output apparent power	55,000	66,000	88,000	110,000	121,000	VA
Peak output power (10 seconds)	75,000	90,000	120,000	150,000	150,000	- W
Nominal output voltage	·	3	80 / 400 / 480, 3W+N-	+PE		V
Nominal output frequency	50 / 60					Hz
Power factor	0.8 leading ~ 0.8 lagging					
Total voltage harmonic distortion	THDv < 3%					
Disruption time of backup switch <sup>2</sup>			0			ms
Efficiency						
Max. efficiency			98.3%			
European efficiency	97.9%	97.9%	98.0%	98.0%	98.0%	
Protection						

Safety protection feature

DC reverse polarity protection, Insulation monitoring, Residual current monitoring, Arc fault circuit interrupter, AC overcurrent/overvoltage/short-circuit protection. Type II DC/AC surge protection, Anti-islanding protection

General Data		
Dimensions (W / H / D)	1110 / 668 / 348	mm
Weight	110	kg
Storage temperature range	-40 ~ 70	°C
Operating temperature range	-30 ~ 60	°C
Relative humidity range	0% ~ 100%	<del></del>
Max. operating altitude	5,000 (Derating at 4,000m)	m
Cooling	Smart air cooling	
Ingress protection rating	IP66	
Communication	WLAN / Fast Ethernet / RS485 / Sigen CommMod (4G/3G/2G)	

## **Standard Compliance**

### IEC / EN 62109-1, IEC / EN 62109-2, IEC / EN 61000-6-1, IEC / EN 61000-6-2

- The requirements for the PV string open-circuit voltage in a PV+ESS DC coupling system are as follows: 1) When the system is configured with 219 battery modules, the string open-circuit voltage should meet the following minimum requirements: 1.1) If configured with 21 battery modules, the string open-circuit voltage should be > 935 V; 1.2) If configured with 20 battery modules, the string open-circuit voltage should be > 870 V; 1.3) If configured with 19 battery modules, the string open-circuit voltage should be > 805 V. 2) When the system is configured with 4 to 18 battery modules, the string open-circuit voltage has no special requirements.
- This refers to the load-side disruption time. Test conditions: In the open-circuit state of the power grid, the total power of the Sigen Hybrid Inverter is higher than the total
- For all standards refer to the certificates category on the Sigenergy website.
- For Sigen energy gateway connections, the inverter should be connected to the gateway via its AC output port (Grid).
- The information in this document reflects the current state of technology and is subject to change without notice. For the latest updates, please refer to the Sigenerary Disclaimer: The information in this file is provided on an "as is" basis. To the fullest extent permitted by law, Sigenergy Technology Co., Ltd. excludes all representations and warranties relating to this file and its contents or which is or may be provided by any affiliates or any other third party, including in relation to any inaccuracies or omissions in this file.